



November 07, 2017

Colleen Wronski
Lincoln Way Special Education District 843
601 Willow Street
Frankfort, IL 60423

Workorder: 1710M49

TEL: (815) 806-4625

FAX:

RE: Drinking Water Lead Analysis

Dear Colleen Wronski:

Suburban Laboratories, Inc. received 32 sample(s) on 10/30/2017 for the analyses presented in the following report.

Customer has provided 250 mL volume sample bottles for all samples collected. Please note, all sample results that exceed 5.00 ug/L should be promptly reported to parents or guardians of all enrolled students. Results that are below 5.00 ug/L should be reported on the school website. Please refer to Public Act 099-0922 or the Illinois Department of Public Health for specific reporting requirements. Suburban Laboratories will forward all results to the IDPH within seven (7) business days from the date of this report.

This report may not be reproduced, except in full, without the prior written approval of Suburban Laboratories, Inc. If you have any questions regarding these test results, please call me at (708) 544-3260.

Sincerely,

A handwritten signature in black ink, appearing to read 'Pat Rodriguez', is written over a light blue horizontal line.

Pat Rodriguez
Project Manager
708-544-3260 ext 214
pat@suburbanlabs.com



SUBURBAN LABORATORIES, Inc.



1950 S. Batavia Ave., Suite 150 Geneva, Illinois 60134
Tel. (708) 544-3260 • Toll Free (800) 783-LABS
Fax (708) 544-8587
www.suburbanlabs.com

Client ID: Lincoln Way Special Education District 843
Project Name: Drinking Water Lead Analysis

Report Date: November 07, 2017
Workorder: 1710M49

Analyte: Lead

Method: EPA 200.8

Matrix: Drinking Water

Sample ID	Client Sample ID	Result	MRL	Units	Date & Time Water System Last Used	Date Collected	Date Analyzed
1710M49-001A	102 1st Draw	9.07	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-002A	102 2nd Draw	7.53	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-003A	103 1st Draw	5.89	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-004A	103 2nd Draw	3.07	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-005A	104 1st Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-006A	104 2nd Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-007A	105 1st Draw	10.9	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-008A	105 2nd Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-009A	106 1st Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/6/2017
1710M49-010A	106 2nd Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-011A	Kitchen #1 1st Draw	12.6	2.00	µg/L	10/25/17 20:15	10/25/2017	11/6/2017
1710M49-012A	Kitchen #1 2nd Draw	2.52	2.00	µg/L	10/25/17 20:15	10/25/2017	11/6/2017
1710M49-013A	Nurse 1st Draw	2.30	2.00	µg/L	10/25/17 20:15	10/25/2017	11/6/2017
1710M49-014A	Nurse 2nd Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-015A	208 1st Draw	55.1	2.00	µg/L	10/25/17 20:15	10/25/2017	11/6/2017
1710M49-016A	208 2nd Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-017A	207 1st Draw	2.01	2.00	µg/L	10/25/17 20:15	10/25/2017	11/6/2017
1710M49-018A	207 2nd Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-019A	206 1st Draw	4.65	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-020A	206 2nd Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-021A	205 1st Draw	525	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-022A	205 2nd Draw	2.49	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-023A	204 1st Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-024A	204 2nd Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-025A	203 1st Draw	4.31	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-026A	203 2nd Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-027A	202 1st Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-028A	202 2nd Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-029A	307 1st Draw	3.33	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-030A	307 2nd Draw	ND	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-031A	310 1st Draw	5.41	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017
1710M49-032A	310 2nd Draw	6.27	2.00	µg/L	10/25/17 20:15	10/25/2017	11/3/2017

FIELD DATA FORM

This form must be filled out completely and returned with samples

School/Facility Name	Address	Sample Collector Name(s)
Lincoln Way Special Education District 843	601 Willow Street Frankfort IL 60423	COLLEEN WRONSKI GILBERTO BELTRAN

Water System Last Used	Date: 10/25/17	Time: 8:15 pm
------------------------	----------------	---------------

Room/Location ID	Source Type	Room Use	First Draw=1 Flush=2	Collection Date	Collection Time	ID A-Z	Comments	
102	S	102		6:35	6:36		1710A49-001A ↓	
103	S	103		6:40	6:41			
104	S	104		6:43	6:44			
105	S	105		6:45	6:46			
106	S	106		6:48	6:49			
Kitchen #1	S	210B		6:51	6:52			
NURSE	S	200C		6:54	6:55			
208	S	208		6:56	6:57			
207	S	207		6:59	6:7:00			
206	S	206		7:02	7:03			
205	S	205		7:05	7:06			
204	S	204		7:10	7:11			
203	S	203		7:13	7:14			
202	S	202		7:15	7:16			
307	S	307		7:18	7:19			
310	S	310		7:21	7:22			30A